



Legionella Test Report

Customer Details

Report No. WA-R-L-2103-39920

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2103-05596 Received Date : 27/03/2021 Sample No. : WA-S-L-2103-39427

Sampling Date	: 27/03/2021	Report Date.	: 06/04/2021
Analysis Start Date.	: 27/03/2021	Analysis End Date.	: 06/04/2021
Sample Location.	: Etihad Airways	Sampled By	: Client rep
Sample Identification	: Not given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: BS7596
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Sterile Plastic bottle	Source of Sample	: Etihad Airways
Sampling Point	: Hanger 6A	Preservation	: 10°C
Sample Description	: Water	Samplerrefno	: 5

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1.0CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on Water Quality Regulations 2021. Document no. DoE/PD/R01/003. Table F – Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2103-39919

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2103-05596 Received Date : 27/03/2021 Sample No. : WA-S-L-2103-39426

Sampling Date	: 27/03/2021	Report Date.	: 06/04/2021
Analysis Start Date.	: 27/03/2021	Analysis End Date.	: 06/04/2021
Sample Location.	: Etihad Airways	Sampled By	: Client rep
Sample Identification	: Not given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: BS7595
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Sterile Plastic bottle	Source of Sample	: Etihad Airways
Sampling Point	: Bay 06	Preservation	: 10°C
Sample Description	: Water	Samplerrefno	: 4

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1.0CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on Water Quality Regulations 2021. Document no. DoE/PD/R01/003. Table F – Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2103-39918

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2103-05596 Received Date : 27/03/2021 Sample No. : WA-S-L-2103-39425

Sampling Date	: 27/03/2021	Report Date.	: 06/04/2021
Analysis Start Date.	: 27/03/2021	Analysis End Date.	: 06/04/2021
Sample Location.	: Etihad Airways	Sampled By	: Client rep
Sample Identification	: Not given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: BS7594
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Sterile Plastic bottle	Source of Sample	: Etihad Airways
Sampling Point	: Hanger 04	Preservation	: 10°C
Sample Description	: Water	Samplerrefno	: 3

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1.0CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on Water Quality Regulations 2021. Document no. DoE/PD/R01/003. Table F – Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2103-39917

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2103-05596 Received Date : 27/03/2021 Sample No. : WA-S-L-2103-39424

Sampling Date	: 27/03/2021	Report Date.	: 06/04/2021
Analysis Start Date.	: 27/03/2021	Analysis End Date.	: 06/04/2021
Sample Location.	: Etihad Airways	Sampled By	: Client rep
Sample Identification	: Not given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: BS7593
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Sterile Plastic bottle	Source of Sample	: Etihad Airways
Sampling Point	: Utility	Preservation	: 10°C
Sample Description	: Water	Samplerrefno	: 2

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1.0CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on Water Quality Regulations 2021. Document no. DoE/PD/R01/003. Table F – Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2103-39916



Request No. : WA-Q-L-2103-05596 Received Date : 27/03/2021 Sample No. : WA-S-L-2103-39423

Sampling Date	: 27/03/2021	Report Date.	: 06/04/2021
Analysis Start Date.	: 27/03/2021	Analysis End Date.	: 06/04/2021
Sample Location.	: Etihad Airways	Sampled By	: Client rep
Sample Identification	: Not given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: BS7592
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Sterile Plastic bottle	Source of Sample	: Etihad Airways
Sampling Point	: Aviation	Preservation	: 10°C
Sample Description	: Water	Samplerrefno	: 1

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1.0CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on Water Quality Regulations 2021. Document no. DoE/PD/R01/003. Table F – Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -