

TEST REPORT

REPORT NO:-QMTL/R-71233

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-71233
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received: 08.09.2019
Sample Description : SV2 Service Building – Hydraulic RCC – Raw Tank, Domestic Water Sample Onsite Temp: 27°C Sample Receipt Temp: 6°C	Source: Tank	Date(s) Tested: 08-18.09.2019
	Sample Container: 1X 1L PB	Date Reported: 19.09.2019
	Sample Appearance: Clear	Date of Sampling: 08.09.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 29	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANLA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-71234

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-71234
Reference: ZAYED UNIVERSITY – ABU DHABI	Sampled By: QMTL Representative	Date Received: 08.09.2019
Sample Description : Domestic Water – Male Campus - Washroom Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Tank	Date(s) Tested: 08-18.09.2019
	Sample Container: 1X 1L PB	Date Reported: 19.09.2019
	Sample Appearance: Clear	Date of Sampling: 08.09.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 29	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable


Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

"An ISO 9001:2015, ISO14001:2015 & OHSAS 18001:2007 Certified Company"



NAL 079
17025



TEST REPORT

REPORT NO:-QMTL/R-71235

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-71235
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received: 08.09.2019
Sample Description : Domestic Water – Female Campus - Washroom Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 08-18.09.2019
	Sample Container: 1X 1L PB	Date Reported: 19.09.2019
	Sample Appearance: Clear	Date of Sampling: 08.09.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 29	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE

LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

"An ISO 9001:2015, ISO14001:2015 & OHSAS 18001:2007 Certified Company"



NAL 079
17025



TEST REPORT

REPORT NO:-QMTL/R-71236

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

ATTN:MR. JASMAN PINTO

Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-71236
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received: 08.09.2019
Sample Description : Domestic Water – SV 1 Building – Raw Water Tank Sample Onsite Temp: 35°C Sample Receipt Temp: 6°C	Source: Hydraulic Pump Room	Date(s) Tested: 08-18.09.2019
	Sample Container: 1X 1L PB	Date Reported: 19.09.2019
	Sample Appearance: Clear	Date of Sampling: 08.09.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 29	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

"An ISO 9001:2015, ISO14001:2015 & OHSAS 18001:2007 Certified Company"



NAL 079
17025



TEST REPORT

REPORT NO:-QMTL/R-71237

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-71237
Reference: ZAYED UNIVERSITY - ABU DHABI	Sampled By: QMTL Representative	Date Received: 08.09.2019
Sample Description : Domestic Water – SV 1 Building – Filter Water Tank Sample Onsite Temp: 33°C Sample Receipt Temp: 6°C	Source: Hydraulic Pump Room	Date(s) Tested: 08-18.09.2019
	Sample Container: 1X 1L PB	Date Reported: 19.09.2019
	Sample Appearance: Clear	Date of Sampling: 08.09.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 29	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

"An ISO 9001:2015, ISO14001:2015 & OHSAS 18001:2007 Certified Company"



NAL 079
17025



TEST REPORT

REPORT NO: - QMTL/R-71238

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-71238
Reference: ZAYED UNIVERSITY – ABU DHABI	Sampled By: QMTL Representative	Date Received: 08.09.2019
Sample Description : Irrigation Water - SV 1 - Building Sample Onsite Temp: 40°C Sample Receipt Temp: 6°C	Source: Tank	Date(s) Tested: 08-18.09.2019
	Sample Container: 1x 1L PB	Date Reported: 19.09.2019
	Sample Appearance: Clear	Date of Sampling: 08.09.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 29	Location: AUH

TEST RESULTS

PARAMETER	TEST METHOD	UNIT	LIMIT	RESULT
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	100 (cfu/ml) (circulating water)	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Recycled Water and Biosolids Regulations 2018 requirements for irrigation water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association,, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date :03.01.2016