

### TEST REPORT

REPORT NO:-QMTL/R-84093

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84093
Reference: AL GHADEER PROJECT	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> Sahil Swimming Pool Sample Onsite Temp: 28.8°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:00AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable,

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

### TEST REPORT

REPORT NO:-QMTL/R-84094

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84094
Reference: <b>AL GHADER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> Waha Swimming Pool Sample Onsite Temp: 29°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:12AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-84095

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84095
Reference: <b>AL GHAEER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> 6B Swimming Pool Sample Onsite Temp: 31°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:23AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-84096

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84096
Reference: AL GHAEER PROJECT	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> 5A Swimming Pool Sample Onsite Temp: 29.5°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:32AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

### TEST REPORT

REPORT NO:-QMTL/R-84097

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84097
Reference: <b>AL GHAEER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> 5B Swimming Pool Sample Onsite Temp: 30.8°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:43AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-84098

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84098
Reference: <b>AL GHADER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> Water Fall Club House Pool Sample Onsite Temp: 30.8°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:50AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

### TEST REPORT

REPORT NO:-QMTL/R-84099

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84099
Reference: AL GHAEDEER PROJECT	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> 4A Swimming Pool Sample Onsite Temp: 28.6°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/11:59AM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

### TEST REPORT

REPORT NO:-QMTL/R-84100

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84100
Reference: <b>AL GHADER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> 4C Swimming Pool Sample Onsite Temp: 30.6°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/12:08PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-84101

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84101
Reference: <b>AL GHADER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> Zone 3 Swimming Pool Sample Onsite Temp: 30.1°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/12:20PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-84102

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84102
Reference: <b>AL GHADEER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> Breeze Club House Pool Sample Onsite Temp: 32°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/12:39PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-84103

<b>CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-84103
Reference: <b>AL GHADER PROJECT</b>	Sampled By: QMTL Representative	Date Received: 12.12.2019
<b>Sample Description:</b> 7B Swimming Pool Sample Onsite Temp: 31°C Sample Receipt Temp: 16°C	Source: Pool	Date(s) Tested: 12-22.12.2019
	Sample Container: 1x1 L PB	Date Reported: 23.12.2019
	Sample Appearance: Clear	Date of Sampling/Time: 12.12.2019/12:48PM
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable,

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016