

## TEST REPORT

REPORT NO:-QMTL/R-86757

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-86757
Reference: AL BATEEN PARK	Sampled By: Client Representative	Date Received: 04.01.2020
<b>Sample Description :</b> Swimming Pool Sample Onsite Temp: 30°C Sample Receipt Temp: 28°C	Source: Pool	Date(s) Tested: 04.01.2020-14.01.2020
	Sample Container: 1x1L PB	Date Reported: 09.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/11:30AM
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT