

TEST REPORT

Report No: QMTL/R-101667/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO	Sample ID	QMTL/S-101667
	Date Received	23 Apr 2020
	Date(s) Tested	23 Apr 2020- 03 May 2020
	Date Reported	05 May 2020
Sample Description	Potable Water, RCC Tank	
Sample Type	Water	Sampling Method NP
Client Name/Project	NP	Sampled By Client Representative
Location	Serco Staff Accommodation	Sampling Date/Time 23.04.2020/NP
Sample Container	1x1L PB	Sampling Point Tank
Sample Receipt Temp	19°C	Sample On-site Temp 26°C
Sample Appearance	Clear	On-site Treatment NP
Reference	NP	

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A, Procedure 5)	CFU/litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB : Regulation & Supervision Bureau, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar Culture Media :- BCYE Agar
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-101668/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO	Sample ID	QMTL/S-101668	
	Date Received	23 Apr 2020	
	Date(s) Tested	23 Apr 2020-03 May 2020	
	Date Reported	05 May 2020	
Sample Description	Potable Water, Apartment 1		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Serco Staff Accommodation	Sampling Date/Time	23.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	19°C	Sample On-site Temp	27°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A, Procedure 5)	CFU/litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB : Regulation & Supervision Bureau, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar Culture Media :- BCYE Agar
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-101669/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO	Sample ID	QMTL/S-101669	
	Date Received	23 Apr 2020	
	Date(s) Tested	23 Apr 2020-03 May 2020	
	Date Reported	05 May 2020	
Sample Description	Potable water, Apartment 2		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Serco Staff Accommodation	Sampling Date/Time	23.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	19°C	Sample On-site Temp	26.9°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A, Procedure 5)	CFU/litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB : Regulation & Supervision Bureau, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar Culture Media :- BCYE Agar
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-101670/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		Sample ID	QMTL/S-101670
		Date Received	23 Apr 2020
		Date(s) Tested	23 Apr 2020- 03 May 2020
		Date Reported	05 May 2020
Sample Description	Hot Water		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Serco Staff Accommodation	Sampling Date/Time	23.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	19°C	Sample On-site Temp	36°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A, Procedure 5)	CFU/litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB : Regulation & Supervision Bureau, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar Culture Media :- BCYE Agar
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT