

TEST REPORT

REPORT NO: - QMTL/R-86950

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86950
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 14, GRP Tank- 1 Sample Onsite Temp: 25.4°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.15 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86951

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86951
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 15, GRP Tank- 1 Sample Onsite Temp: 26°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.23 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86952

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86952
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 15, GRP Tank- 2 Sample Onsite Temp: 26.4°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.31 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86953

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86953
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 6, GRP Tank Sample Onsite Temp: 29.6°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.40 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86954

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86954
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Tennis Academy, GRP Tank- 1 Sample Onsite Temp: 22°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.48 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86955

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86955
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Tennis Academy, GRP Tank- 2 Sample Onsite Temp: 23.4°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.56 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT



TEST REPORT

REPORT NO: - QMTL/R-86956

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86956
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Tennis Academy, Roof Tank- 3 Sample Onsite Temp: 25.1°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.04 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86957

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86957
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Club House Main Tank RCC, Ground Tank Sample Onsite Temp: 30.4°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.11 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86958

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86958
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Club House Filtration Tank, Ground Tank Sample Onsite Temp: 29.8°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.18 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86959

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86959
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Agronomy RCC Tank, Outside Ground Tank Sample Onsite Temp: 33.2°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.37 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86960

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86960
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : ETP- 1, GRP Tank, Roof Tank- 1 Sample Onsite Temp: 23.2°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.45 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86961

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86961
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : ETP- 1, GRP Tank, Roof Tank- 2 Sample Onsite Temp: 23.4°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.57 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86962

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID : QMTL/S- 86962
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : ETP- 1, GRP Tank, Roof Tank- 3 Sample Onsite Temp: 23.6°C Sample Receipt Temp: 17°C	Source: Tank	Date(s) Tested : 04.01.2020-14.01.2020
	Sample Container: 1 X 1L PB	Date Reported : 19.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/04.17 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT