

TEST REPORT

Report No: QMTL/R-102220/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-102220
ATTN : MR. JASMAN PINTO		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020 - 10 May 2020
		Date Reported	11 May 2020
Sample Description	Main Utility		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35.1°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102221/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-102221
ATTN : MR. JASMAN PINTO		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020 - 10 May 2020
		Date Reported	11 May 2020
Sample Description	Aviation		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35.1°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102222/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-102222	
	Date Received	30 Apr 2020	
	Date(s) Tested	30 Apr 2020 - 10 May 2020	
	Date Reported	11 May 2020	
Sample Description	Hanger-04		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35.1°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		


TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102223/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-102223
ATTN : MR. JASMAN PINTO		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020 - 10 May 2020
		Date Reported	11 May 2020
Sample Description	Hanger-05		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Ethihad Airways Engineering	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35.1°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		


TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102224/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-102224	
	Date Received	30 Apr 2020	
	Date(s) Tested	30 Apr 2020 - 10 May 2020	
	Date Reported	11 May 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	Bay-06		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35.1°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT