



Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12105

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11697
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Main Tank
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





Microbiology Test Report

Report No. : WA-R-L-2006-12105

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2006-12106



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11697
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Main Tank
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection= \leq 1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	22-06-2020
Sampled By	Crystalline Rep	Sample Location	RCC WATER TANK
Sample Type	Potable Water		

TEST RESULT

Physical Parameters			
	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.45
2	Conductivity at 25°C, µs/cm	----	132
3	Total Dissolved Solids (TDS)	Max 1000	85
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.36
7	Calcium Hardness at 25°C	200	55
8	Total Hardness at 25°C	300	69
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	49
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05


*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine levels are normal
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj
Service Engineer





Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12107

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971
265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11698
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Kitchen Water Tap
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





مختبرات ويمبي ذ.م.م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Microbiology Test Report

Report No. : WA-R-L-2006-12107

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2006-12108

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11698
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Kitchen Water Tap
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	22-06-2020
Sampled By	Crystalline Rep	Sample Location	Kitchen Cooking Area
Sample Type	Potable Water		

TEST RESULT			
	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.83
2	Conductivity at 25°C, µs/cm	----	135
3	Total Dissolved Solids (TDS)	Max 1000	87
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.32
7	Calcium Hardness at 25°C	200	60
8	Total Hardness at 25°C	300	73
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	51
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05


*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS	
1	PH, Conductivity & TDS levels are normal.
2	Residual chlorine level is satisfactory
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj

Service Engineer





Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12109

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11699
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Cooler Tap (Near Main Tank)
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





مختبرات ويمبي ذ م م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Microbiology Test Report

Report No. : WA-R-L-2006-12109

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2006-12110

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11699
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Cooler Tap (Near Main Tank)
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	22-06-2020
Sampled By	Crystalline Rep	Sample Location	Water Cooler
Sample Type	Potable Water		

TEST RESULT

Physical Parameters

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.61
2	Conductivity at 25°C, µs/cm	----	119
3	Total Dissolved Solids (TDS)	Max 1000	77
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.29
7	Calcium Hardness at 25°C	200	42
8	Total Hardness at 25°C	300	56

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	36
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05


*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is satisfactory
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

P. Murugaraaj
Murugaraaj
Service Engineer





Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12111

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11700
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Washroom Tap (Near Cooler Tap)
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





مختبرات ويمبي ذ.م.م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2006-12111

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without Laboratory approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2006-12112



Request No.	: WA-Q-L-2006-01862	Sample No.	: WA-S-L-2006-11700
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Mountain Gate	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Washroom Tap (Near Cooler Tap)
Sampling Point	: Not Given	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection= <1 CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	22-06-2020
Sampled By	Crystalline Rep	Sample Location	Wash Room
Sample Type	Potable Water		

TEST RESULT

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.73
2	Conductivity at 25°C, µs/cm	----	129
3	Total Dissolved Solids (TDS)	Max 1000	83
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.37
7	Calcium Hardness at 25°C	200	52
8	Total Hardness at 25°C	300	64

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	46
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Residual chlorine level is satisfactory
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraa
Murugaraa
Service Engineer

