



# CRYSTALLINE ENVIRONMENTAL SERVICES

## CONSULTING TEST REPORT

CUSTOMER: TAFAWUQ FACILITY MANAGEMENT	DATE: 07-09-2020
SITE LOCATION: C2 BUILDING	SAMPLE POINT: ETS - ROOM

### CHILLED WATER ANALYSIS

PARAMETER	CONTROL LIMITS	RESULTS
pH	9.0 - 10.5	10.02
Conductivity, $\mu\text{s}/\text{cm}$	Max 3500	1730
TDS, ppm	--	1124
Iron, ppm as Fe	0 - 2.0	0.07
<b>Treatment Residuals</b>		
Nitrite, ppm	> 800	870
Dipslide	<10 <sup>3</sup>	ND

\*\*\*All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity ( $\mu\text{mhos}$ ).

COMMENTS:	ACTION:
The pH level is satisfactory $\Rightarrow$	No action recommended.
The Conductivity levels are satisfactory $\Rightarrow$	No action recommended.
Dissolved iron levels are within the control limits. $\Rightarrow$	No action recommended.
Corrosion Inhibitor levels are satisfactory $\Rightarrow$	No action recommended.

Reported By

Murugaraaj  
Service Engineer



**CLEANER WATER GREENER TOMORROW**



# CRYSTALLINE ENVIRONMENTAL SERVICES

## CONSULTING TEST REPORT

CUSTOMER: TAFAWUQ FACILITY MANAGEMENT	DATE: 07-09-2020
SITE LOCATION: C3 BUILDING	SAMPLE POINT: ETS- ROOM

### CHILLED WATER ANALYSIS

PARAMETER	CONTROL LIMITS	RESULTS
pH	9.0 - 10.5	10.20
Conductivity, $\mu\text{s}/\text{cm}$	Max 3500	1930
TDS, ppm	--	1254
Iron, ppm as Fe	0 - 2.0	0.09
<b>Treatment Residuals</b>		
Nitrite, ppm	> 800	840
Dipslide	<10 <sup>3</sup>	ND

\*\*\*All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity ( $\mu\text{mhos}$ ).

COMMENTS:	ACTION:
The pH level is satisfactory $\Rightarrow$	No action recommended.
The Conductivity levels are satisfactory $\Rightarrow$	No action recommended.
Dissolved iron levels are within the control limits. $\Rightarrow$	No action recommended.
Corrosion Inhibitor levels are satisfactory $\Rightarrow$	No action recommended.

Reported By

  
Murugaraaj  
Service Engineer



**CLEANER WATER GREENER TOMORROW**