

## TEST REPORT

Report No: QMTL/R-102339/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-102339
		Date Received	03 May 2020
		Date(s) Tested	03 May 2020 - 05 May 2020
<b>ATTN</b> : MR. JASMAN PINTO		Date Reported	09 May 2020
Sample Description	Main Pool		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Al Bateem Park Villas	Sampling Date/Time	03.05.2020/ NP
Sample Container	1X500ml PB	Sampling Point	Pool
Sample Receipt Temp	32.5°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	1000	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**