



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9201

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8998
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Admin Building (Tap Water)
Sampling Point	: Cup 02	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9200

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8997
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Pump House (Tap Water)
Sampling Point	: Cup 02	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9199

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8996
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Guard House (Tap Water)
Sampling Point	: Cup 02	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9198

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8995
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Admin Building (Tap Water)
Sampling Point	: Cup 01	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9197

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8994
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Pump House (Tap Water)
Sampling Point	: Cup 01	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9196

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8993
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Guard House (Tap Water)
Sampling Point	: Cup 01	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-9195

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1449	Sample No.	: WA-S-L-2005-8992
Sampling Date/time	: 13/5/2020 , 06:20	Report Date.	: 18/5/2020
Analysis Start Date.	: 16/5/2020	Analysis End Date.	: 18/5/2020
Sample Location.	: Midfield Terminal - Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: APHA 9060 A & B
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Switching Station (Tap Water)
Sampling Point	: Cup 01	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -