

TEST REPORT

REPORT NO: - QMTL/R-86936

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86936
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 14, GRP Tank- 1 Sample Onsite Temp: 25.4°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.15 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86937

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86937
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 15, GRP Tank- 1 Sample Onsite Temp: 26°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.23 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86938

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86938
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 15, GRP Tank- 2 Sample Onsite Temp: 26.4°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.31 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86939

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86939
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Comfort Station- 6, GRP Tank Sample Onsite Temp: 29.6°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.40 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86940

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86940
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Tennis Academy, GRP Tank- 1 Sample Onsite Temp: 22°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.48 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86941

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86941
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Tennis Academy, GRP Tank- 2 Sample Onsite Temp: 23.4°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/02.56 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86942

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86942
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Tennis Academy, Roof Tank- 3 Sample Onsite Temp: 25.1°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.04 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86943

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86943
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Club House Main Tank RCC, Ground Tank Sample Onsite Temp: 30.4°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.11 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86944

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86944
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Club House Filtration Tank, Ground Tank Sample Onsite Temp: 29.8°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.18 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86945

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86945
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Chiller Water Sample Onsite Temp: 9°C Sample Receipt Temp: 4.5°C	Source: Valve	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.25 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10,000	2
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality 2010 specifications for Cooling Water System with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86946

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86946
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : Agronomy RCC Tank, Outside Ground Tank Sample Onsite Temp: 33.2°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.37 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86947

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86947
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : ETP- 1, GRP Tank, Roof Tank- 1 Sample Onsite Temp: 23.2°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.45 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86948

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86948
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : ETP- 1, GRP Tank, Roof Tank- 2 Sample Onsite Temp: 23.4°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/03.57 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-86949

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 86949
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 04.01.2020
Sample Description : ETP- 1, GRP Tank, Roof Tank- 3 Sample Onsite Temp: 23.6°C Sample Receipt Temp: 4.5°C	Source: Tank	Date(s) Tested : 04.01.2020-06.01.2020
	Sample Container: 1 X 500ml PB	Date Reported : 08.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 04.01.2020/04.17 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT