

TEST REPORT

Report No: QMTL/R-128326/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128326
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
		Date Reported	19 Oct 2020
Sample Description	Cup - 1, Admin Building		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128327/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128327
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
		Date Reported	19 Oct 2020
Sample Description	Cup - 1, SWS (Switching Station)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128328/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128328
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
		Date Reported	19 Oct 2020
Sample Description	Cup - 1, GH (Guard House)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128329/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128329
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
		Date Reported	19 Oct 2020
Sample Description	Cup - 1, PH (Pump House)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128330/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128330
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
		Date Reported	19 Oct 2020
Sample Description	Cup - 2, Admin Building		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128331/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128331
		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
ATTN : MR. JASMAN PINTO		Date Reported	19 Oct 2020
Sample Description	Cup - 2, GH (Guard House)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128332/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128332
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 15 Oct 2020
		Date Reported	19 Oct 2020
Sample Description	Cup - 2, PH (Pump House)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x500ml PB	Sampling Point	NP
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128333/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128333
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
		Date Reported	26 Oct 2020
Sample Description	Cup - 1, Admin Building		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 03
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128334/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128334
		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
ATTN : MR. JASMAN PINTO		Date Reported	26 Oct 2020
Sample Description	Cup - 1, SWS (Switching Station)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 03
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128335/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128335
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
		Date Reported	26 Oct 2020
Sample Description	Cup - 1, GH (Guard House)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 03
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128336/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128336
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
		Date Reported	26 Oct 2020
Sample Description	Cup - 1, PH (Pump House)		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pnueumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnueumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 03
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128337/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-128337
		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
		Date Reported	26 Oct 2020
Sample Description	Cup - 2, Admin Building		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pnueumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnueumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 03
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128338/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128338
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
		Date Reported	26 Oct 2020
Sample Description	Cup - 2, (GH) Guard House		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 03
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128339/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128339
ATTN : MR. JASMAN PINTO		Date Received	13 Oct 2020
		Date(s) Tested	13 Oct 2020 - 23 Oct 2020
		Date Reported	26 Oct 2020
Sample Description	Cup - 2,(PH) Pump House		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Midfield Terminal	Sampling Date/Time	13.10.2020 / NP
Sample Container	1x1L PB	Sampling Point	NP
Sample Receipt Temp	21°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 03
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT