

**TEST REPORT**

REPORT NO:-QMTL/R-75837

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75837
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Admin Building Cup- 1 Sample Onsite Temp: 28°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75838

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75838
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Admin Building Cup- 2 Sample Onsite Temp: 26°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>210**</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:\*\*The sample does not meet RSB Water Quality Regulation (4<sup>th</sup> Edition) January 2014 requirement for potable water with respect to the above test only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75839

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75839
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Guard House Cup- 1 Sample Onsite Temp: 27°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75840

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75840
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Guard House Cup- 2 Sample Onsite Temp: 28°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>220**</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample does not meet RSB Water Quality Regulation (4<sup>th</sup> Edition) January 2014 requirement for potable water with respect to the above test only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75841

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75841
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Pump House Cup- 1 Sample Onsite Temp: 26°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75842

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75842
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Pump House Cup- 2 Sample Onsite Temp: 27°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>240**</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: \*\*The sample does not meet RSB Water Quality Regulation (4<sup>th</sup> Edition) January 2014 requirement for potable water with respect to the above test only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75843

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID : QMTL/S-75843
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received : 13.10.2019
<b>Sample Description :</b> Switching Station Cup- 1 Sample Onsite Temp: 28°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested : 13-15.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75844

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75844
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Admin Building Cup- 1 Sample Onsite Temp: 28°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75845

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75845
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Admin Building Cup- 2 Sample Onsite Temp: 26°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-75846

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75846
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Guard House Cup- 1 Sample Onsite Temp: 27°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-75847

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75847
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Guard House Cup- 2 Sample Onsite Temp: 28°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-75848

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75848
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Pump House Cup- 1 Sample Onsite Temp: 26°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueomphila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueomphila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75849

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75849
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Pump House Cup- 2 Sample Onsite Temp: 27°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-75850

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-75850
Reference: <b>MID FIELD TERMINAL</b>	Sampled By: Client Representative	Date Received: 13.10.2019
<b>Sample Description :</b> Switching Station Cup- 1 Sample Onsite Temp: 28°C Sample Receipt Temp: 7°C	Source: Tap	Date(s) Tested: 13-23.10.2019
	Sample Container: 1X 1L PB	Date Reported: 26.10.2019
	Sample Appearance: Clear	Date of Sampling: 13.10.2019/4.45 PM
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**