



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24272



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23501

Sampling Date	: 25/10/2020	Report Date.	: 27/10/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 27/10/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Washroom Tap
Sampling Point	: Near Cooler	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24271



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23500

Sampling Date	: 25/10/2020	Report Date.	: 27/10/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 27/10/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Cooler Tap
Sampling Point	: Near Kitchen	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24270



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23499

Sampling Date	: 25/10/2020	Report Date.	: 27/10/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 27/10/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Kitchen Tap
Sampling Point	: Near D Block	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24269



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23498

Sampling Date	: 25/10/2020	Report Date.	: 27/10/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 27/10/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Main Tank
Sampling Point	: Near Kitchen	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24276



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23505

Sampling Date	: 25/10/2020	Report Date.	: 04/11/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 04/11/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Washroom Tap
Sampling Point	: Near Cooler	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24275



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23504

Sampling Date	: 25/10/2020	Report Date.	: 04/11/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 04/11/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Cooler Tap
Sampling Point	: Near Kitchen	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24274



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23503

Sampling Date	: 25/10/2020	Report Date.	: 04/11/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 04/11/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Kitchen Tap
Sampling Point	: Near D Block	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2010-24273



Request No. : WA-Q-L-2010-03528

Sample No. : WA-S-L-2010-23502

Sampling Date	: 25/10/2020	Report Date.	: 04/11/2020
Analysis Start Date.	: 25/10/2020	Analysis End Date.	: 04/11/2020
Sample Location.	: Mountain Gate Properties	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Given
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Main Tank
Sampling Point	: Near Kitchen	Preservation	: Not Given
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



CRYSTALLINE ENVIRONMENTAL SERVICES

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	25-10-2020
Sampled By	Crystalline Rep	Sample Location	RCC MAIN WATER TANK
Sample Type	Potable Water		

TEST RESULT			
	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.49
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	192
3	Total Dissolved Solids (TDS)	Max 1000	124
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.28
7	Calcium Hardness at 25°C	200	71
8	Total Hardness at 25°C	300	79
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	61
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS	
1	PH, Conductivity & TDS levels are normal
2	Residual chlorine levels are normal
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraa
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	25-10-2020
Sampled By	Crystalline Rep	Sample Location	Water Cooler Tap
Sample Type	Potable Water		

TEST RESULT

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.33
2	Conductivity at 25°C, µs/cm	----	159
3	Total Dissolved Solids (TDS)	Max 1000	103
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.23
7	Calcium Hardness at 25°C	200	69
8	Total Hardness at 25°C	300	77
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	60
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is satisfactory
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,


Murugaraaj
Service Engineer





CRYSTALLINE ENVIRONMENTAL SERVICES

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	25-10-2020
Sampled By	Crystalline Rep	Sample Location	Kitchen Cooking Area Tap
Sample Type	Potable Water		

TEST RESULT			
	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.30
2	Conductivity at 25°C, µs/cm	----	168
3	Total Dissolved Solids (TDS)	Max 1000	109
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 – 0.5	0.24
7	Calcium Hardness at 25°C	200	62
8	Total Hardness at 25°C	300	73

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	55
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Residual chlorine level is satisfactory
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraa
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

POTABLE WATER ANALYSIS REPORT

Client Name: Mountain Gate Property Investment LLC.			
Site location	Mountain Gate Labour Camp	Service Visit:	25-10-2020
Sampled By	Crystalline Rep	Sample Location	Wash Room Tap
Sample Type	Potable Water		

TEST RESULT

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.27
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	151
3	Total Dissolved Solids (TDS)	Max 1000	98
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	0.24
7	Calcium Hardness at 25°C	200	70
8	Total Hardness at 25°C	300	75

Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	61
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Residual chlorine level is satisfactory
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaran
Service Engineer



CLEANER WATER GREENER TOMORROW