

**TEST REPORT**

REPORT NO:-QMTL/R-86755

|   |                                   |  |
|---|-----------------------------------|--|
| <b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>  |                                   |  |
| P.O.Box.131463, Abu Dhabi, U.A.E<br>Ph:02-6508930/0557167017  |                                   |  |
| <b>ATTN: Mr. JASMAN PINTO</b>   |                                   |  |
| Product: Water  | Sampling Method: NA               | Sample ID: QMTL/S-86755                      |
| Reference: <b>AL NOOR TOWER</b>   | Sampled By: Client Representative | Date Received: 04.01.2020                    |
| <b>Sample Description :</b><br>Swimming Pool<br>Sample Onsite Temp: 29°C<br>Sample Receipt Temp: 27°C | Source: Pool                      | Date(s) Tested:<br>04.01.2020-14.01.2020     |
|   | Sample Container: 1x1L PB         | Date Reported: 19.01.2020                    |
|   | Sample Appearance: Clear          | Date of Sampling/Time:<br>04.01.2020/01:30PM |
| On-Site Treatment: NA   | Tested by Emp#: 55 & 78           | Location: AUH                                |

**TEST RESULTS**

| PARAMETERS                             | TEST METHODS                             | UNITS     | LIMITS | RESULTS             |
|--|--|-----------|--------|---------------------|
| <b>LEGIONELLA ANALYSIS</b>             |  |           |        |                     |
| Legionella                             | CCFRA 3.9.1<br>(5 <sup>th</sup> Edition) | cfu/litre | <1     | <b>Not Detected</b> |
| <b>IDENTIFICATION</b>                  |  |           |        |                     |
| Legionella Species                     | CCFRA 3.9.1<br>(5 <sup>th</sup> Edition) | -         | -      | <b>Absent</b>       |
| Legionella pneumophila sero group 1    | CCFRA 3.9.1<br>(5 <sup>th</sup> Edition) | -         | -      | <b>Absent</b>       |
| Legionella pneumophila sero group 2-15 | CCFRA 3.9.1<br>(5 <sup>th</sup> Edition) | -         | -      | <b>Absent</b>       |

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**