

TEST REPORT

Report No: QMTL/R-98864/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98864
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	Waha, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/2:00 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	30°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98865/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98865
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	7B, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/2:11 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	25.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98866/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98866
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	Zone 3, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/2:16 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	27.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent


Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98867/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98867
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	Breeze Club House, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/2:27 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	29.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98868/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98868
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	Zone 4C, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/2:45 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent


Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98869/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-98869	
	Date Received	23 Mar 2020	
	Date(s) Tested	23 Mar 2020 - 02 Apr 2020	
	Date Reported	04 Apr 2020	
Sample Description	Zone 4A, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/3:01 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	30.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent


Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98870/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-98870	
	Date Received	23 Mar 2020	
	Date(s) Tested	23 Mar 2020 - 02 Apr 2020	
	Date Reported	04 Apr 2020	
Sample Description	Water Fall Club House, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/3:15 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	29.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98871/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98871
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	Zone 5B, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/3:25 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	29.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98872/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98872
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	Zone 5A, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/3:29 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	28.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98873/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98873
		Date Received	23 Mar 2020
		Date(s) Tested	23 Mar 2020 - 02 Apr 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Apr 2020
Sample Description	6B, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/3:32 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	29.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-98874/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-98874	
	Date Received	23 Mar 2020	
	Date(s) Tested	23 Mar 2020 - 02 Apr 2020	
	Date Reported	04 Apr 2020	
Sample Description	Sabil, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	23.03.2020/3:40 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	21°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets DM Water Systems quality(2010) specifications for Pool Water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT