

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN: MR. JASMAN PINTO	Sample ID	QMTL/S-95370	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020-28 Feb 2020	
	Date Reported	11 Mar 2020	
Sample Description	Syntax Water Tank # 01		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:00 PM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	4°C	Sample On-site Temp	19°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Escherichia coli	APHA 9222 H & I (23 RD EDITION))	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D (23 RD EDITION))	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23 RD EDITION))	CFU/100ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23 RD EDITION))	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23 RD EDITION))	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirement for potable water with respect to the above tests only. This report supersedes the report no QMTL/R-95370 reported on 02 Mar 2020.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, WI: Work Instruction
----------	--

Test Method Deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-95371	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020-28 Feb 2020	
	Date Reported	11 Mar 2020	
ATTN: MR. JASMAN PINTO			
Sample Description	Syntax Water Tank # 02		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:08 PM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	4°C	Sample On-site Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Escherichia coli	APHA 9222 H & I (23 RD EDITION))	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D (23 RD EDITION))	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23 RD EDITION))	CFU/100ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23 RD EDITION))	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23 RD EDITION))	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirement for potable water with respect to the above tests only. This report supersedes the report no QMTL/R-95371 reported on 02 Mar 2020.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, WI: Work Instruction
----------	--

Test Method Deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-95372	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020-28 Feb 2020	
	Date Reported	11 Mar 2020	
ATTN: MR. JASMAN PINTO			
Sample Description	Syntax Water Tank # 03		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:20 PM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	4°C	Sample On-site Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Escherichia coli	APHA 9222 H & I (23 RD EDITION))	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D (23 RD EDITION))	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23 RD EDITION))	CFU/100ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23 RD EDITION))	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23 RD EDITION))	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirement for potable water with respect to the above tests only. This report supersedes the report no QMTL/R-95372 reported on 02 Mar 2020.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, WI: Work Instruction
----------	--

Test Method Deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN: MR. JASMAN PINTO	Sample ID	QMTL/S-95373	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020-28 Feb 2020	
	Date Reported	11 Mar 2020	
Sample Description	Syntax Water Tank # 04		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:30 PM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	4°C	Sample On-site Temp	11.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Escherichia coli	APHA 9222 H & I (23 RD EDITION))	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D (23 RD EDITION))	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23 RD EDITION))	CFU/100ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23 RD EDITION))	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23 RD EDITION))	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirement for potable water with respect to the above tests only. This report supersedes the report no QMTL/R-95373 reported on 02 Mar 2020.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, WI: Work Instruction
----------	--

Test Method Deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-95374/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID Date Received Date(s) Tested Date Reported	QMTL/S-95374 26 Feb 2020 26 Feb 2020 - 07 Mar 2020 11 Mar 2020
Sample Description	Syntax Water Tank # 01	
Sample Type	Water	Sampling Method
Client Name/Project	NP	Sampled By
Location	AUH	Sampling Date/Time
Sample Container	1x1L PB	Sampling Point
Sample Receipt Temp	20°C	Sample Onsite Temp
Sample Appearance	Clear	On-site Treatment
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND	

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-95375/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-95375	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020 - 07 Mar 2020	
	Date Reported	11 Mar 2020	
Sample Description	Syntax Water Tank # 02		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:08 PM
Sample Container	1x1L PB	Sampling Point	Valve
Sample Receipt Temp	20°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-95376/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-95376	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020 - 07 Mar 2020	
	Date Reported	11 Mar 2020	
Sample Description	Syntax Water Tank # 03		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:15 PM
Sample Container	1x1L PB	Sampling Point	Valve
Sample Receipt Temp	20°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pnueomophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pnueomophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-95377/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-95377	
	Date Received	26 Feb 2020	
	Date(s) Tested	26 Feb 2020 - 07 Mar 2020	
	Date Reported	11 Mar 2020	
Sample Description	Syntax Water Tank # 04		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	26.02.2020/12:30 PM
Sample Container	1x1L PB	Sampling Point	Valve
Sample Receipt Temp	20°C	Sample Onsite Temp	11.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	TAMOUH PROJECT OFFICE, REEM ISLAND		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pnueomophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pnueomophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By


ANILA GEORGE
 LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT