

**TEST REPORT**

REPORT NO:-QMTL/R-64447

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64447
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MR 1, Pantry Sample Onsite Temp: 47°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>1</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64448

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64448
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MR 1 Sample Onsite Temp: 35°C Sample Receipt Temp: 6°C	Source: Plant Room	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64449

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64449
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Convention Centre, Water Fountain Sample Onsite Temp: 39°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64450

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64450
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Convention Centre, Kitchen Sample Onsite Temp: 52°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64451

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64451
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MDH, Kitchen Sample Onsite Temp: 53°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64452

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64452
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MDH, Washroom Sample Onsite Temp: 42°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64453

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64453
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FDH, Kitchen Sample Onsite Temp: 53°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>1</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64454

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64454
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FDH, Washroom Sample Onsite Temp: 42°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>10</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64455

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64455
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FR 1, Kitchen Sample Onsite Temp: 48°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>1</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64456

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64456
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FR 1 Sample Onsite Temp: 42°C Sample Receipt Temp: 6°C	Source: Laundry	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64457

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64457
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Swimming Pool Sample Onsite Temp: 25°C Sample Receipt Temp: 6°C	Source: Pool	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	1000	<b>9</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64458

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64458
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FSP, Washroom Sample Onsite Temp: 35°C Sample Receipt Temp: 6°C	Source: Tap	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>3</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64459

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64459
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FSP Sample Onsite Temp: 48°C Sample Receipt Temp: 6°C	Source: Dining Area	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

**TEST REPORT**

REPORT NO:-QMTL/R-64460

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64460
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, F4, Promenade Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64461

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64461
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, F3, Promenade Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64462

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64462
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, FF2, Central Area Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64463

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64463
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, FF3, Central Area Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64464

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64464
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, MF2, Central Area Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64465

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64465
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, MF3, Central Area Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

**TEST REPORT**

REPORT NO:-QMTL/R-64466

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64466
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, M1, Promenade Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64467

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: APHA 9060 A	Sample ID: QMTL/S-64467
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Fountain, M2, Promenade Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Fountain	Date(s) Tested: 15-17.07.2019
	Sample Container: 1x500 ml PB	Date Reported: 20.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<b>2</b>
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

#### Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT