

**TEST REPORT**

REPORT NO:-QMTL/R-64468

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64468
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MR1, Hot Water Sample Onsite Temp: 47°C Sample Receipt Temp: 6°C	Source: Pantry	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANITA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64469

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64469
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MR1, Hot Water Sample Onsite Temp: 35°C Sample Receipt Temp: 6°C	Source: Plant Room	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueomophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pnueomophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64470

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64470
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Convention Centre, Water Feature Sample Onsite Temp: 39°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-64471

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64471
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Convention Centre, Hot Water Sample Onsite Temp: 52°C Sample Receipt Temp: 6°C	Source: Kitchen	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64472

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64472
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MDH, Hot Water Sample Onsite Temp: 53°C Sample Receipt Temp: 6°C	Source: Kitchen	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64473

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64473
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> MDH, Hot Water Sample Onsite Temp: 42°C Sample Receipt Temp: 6°C	Source: Washroom	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

**TEST REPORT**

REPORT NO:-QMTL/R-64474

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64474
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FDH, Hot Water Sample Onsite Temp: 53°C Sample Receipt Temp: 6°C	Source: Kitchen	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64475

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64475
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FDH, Hot Water Sample Onsite Temp: 42°C Sample Receipt Temp: 6°C	Source: Washroom	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64476

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64476
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FR1, Hot Water Sample Onsite Temp: 48°C Sample Receipt Temp: 6°C	Source: Kitchen	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64477

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64477
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FR1, Hot Water Sample Onsite Temp: 42°C Sample Receipt Temp: 6°C	Source: Laundry	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64478

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64478
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Swimming Pool Water Sample Onsite Temp: 25°C Sample Receipt Temp: 6°C	Source: Swimming Pool	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

**TEST REPORT**

REPORT NO:-QMTL/R-64479

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64479
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FSP, Hot Water Sample Onsite Temp: 35°C Sample Receipt Temp: 6°C	Source: Washroom	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64480

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64480
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> FSP, Hot Water Sample Onsite Temp: 48°C Sample Receipt Temp: 6°C	Source: Dining Area	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS:The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64481

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64481
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Promenade, F4 Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64482

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64482
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Promenade, F3 Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

### TEST REPORT

REPORT NO:-QMTL/R-64483

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64483
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Central Area, FF2 Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61  
Test Method deviation : None  
The above test results are only applicable to the sample(s) referred above

**Reported By**

  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

### TEST REPORT

REPORT NO:-QMTL/R-64484

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64484
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Central Area, FF3 Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANNA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

### TEST REPORT

REPORT NO:-QMTL/R-64485

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64485
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Central Area, MF2 Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

**TEST REPORT**

REPORT NO:-QMTL/R-64486

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64486
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Central Area, MF3 Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.


Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

### TEST REPORT

REPORT NO:-QMTL/R-64487

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64487
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Promenade, M1 Sample Onsite Temp: 24°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-64488

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-64488
Reference: ZAYED UNIVERSITY	Sampled By: QMTL Representative	Date Received: 15.07.2019
<b>Sample Description :</b> Water Feature, Promenade, M2 Sample Onsite Temp: 23°C Sample Receipt Temp: 6°C	Source: Water Fountain	Date(s) Tested: 15-25.07.2019
	Sample Container: 1x 1L PB	Date Reported: 28.07.2019
	Sample Appearance: Clear	Date of Sampling: 15.07.2019
On-Site Treatment: NA	Tested by Emp#: NA	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	cfu/litre	<1	<b>Not Detected</b>
<b>IDENTIFICATION</b>				
Legionella Species	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 <sup>th</sup> Edition)	-	-	<b>Absent</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Water Feature with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, BS: British Standards, CCFRA: Camden & Chorleywood Food Research Association, DM: Dubai Municipality, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

  
**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**