

**TEST REPORT**

**REPORT NO:-QMTL/R-79816**

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
<b>ATTN:MR. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-79816
Reference: <b>OPERON MIDDLE EAST</b>	Sampled By: Client Representative	Date Received: 14.11.2019
Sample Description : R446 Basement (A&B), Water Tank Sample Onsite Temp: NA Sample Receipt Temp: 20°C	Source: Tank	Date(s) Tested: 14-16.11.2019
	Sample Container: 1X 500ml PB	Date Reported: 18.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.11.2019/NA
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHOD (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>5</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

**REMARKS:**The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**