

TEST REPORT

REPORT NO:-QMTL/R-79817

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-79817
Reference: OPERON MIDDLE EAST	Sampled By: Client Representative	Date Received: 14.11.2019
Sample Description : R446 Basement (C&D), Water Tank Sample Onsite Temp: NA Sample Receipt Temp: 20°C	Source: Tank	Date(s) Tested: 14-16.11.2019
	Sample Container: 1X 500ml PB	Date Reported: 18.11.2019
	Sample Appearance: Clear	Date of Sampling/Time: 14.11.2019/NA
On-Site Treatment: NA	Tested by Emp#: 55 & 74	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHOD (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT