



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9527



Request No.	: WA-Q-L-2005-1498	Sample No.	: WA-S-L-2005-9347
Sampling Date/time	: 19/5/2020 , 11:49	Report Date.	: 26/5/2020
Analysis Start Date.	: 19/5/2020	Analysis End Date.	: 22/5/2020
Sample Location.	: AbuDhabi Investment Authorities (ADIA) - Car Parking	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: N/A
Sample Certificate No	: 0818	Sampling Method	: APHA 9060 A & B
Temperature °C	: 25.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: 05th Floor - Swimming Pool Plant Room - Swimming Pool Balancing Water Tank
Sampling Point	: Tank	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	1000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limit based on: Guide to the Executive Regulations of Law No.(2) for the year of 2012 (Swimming Pool), Issued by the Head of Urban Planning and Municipalities No.(3) for the year 2018, Page No.3.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
JY	SM	None

Key. Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذم م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9527

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -