

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: SERCO FACILITY MANAGEMENT, ABU DHABI			
Site Name:	Zayed University	Visit Date:	18-03-2020
Sampled By:	Crystalline Rep.	Sample Point	Main Swimming Pool
Source of Sample	Swimming Pool		


TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.36
2	Conductivity at 25°C, $\mu\text{s/cm}$	---	648
3	TDS, ppm	Max 1500	421
4	Alkalinity	80 - 120	82
5	Calcium Hardness	200 - 500	236
6	Residual Chlorine	1.0 - 3.0	1.12
7	Cyanuric Acid	20 - 60	26
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- pH level is satisfactory – No action recommended.
- Alkalinity & Cyanuric acid levels are satisfactory – No action recommended.

Reported By,

 Murugaraj
 Service Engineer

