

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	AAL RAYYANA – KHALIFA CITY	Visit Date:	14-04-2020
Sampled By:	Crystalline Rep.	Last Visit:	07-03-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.56
2	Conductivity at 25°C, µs/cm	---	210
3	TDS, ppm	Max 1500	136
4	Alkalinity	80 - 120	94
5	Calcium Hardness	200 - 500	208
6	Residual Chlorine	1.0 - 3.0	1.21
7	Cyanuric Acid	20 - 60	25
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters within control limit only -No action recommended.

Reported By,
Murugaraj
Murugaraj
Service Engineer

