



CONSULTING SERVICE REPORT

CUSTOMER: SERCO, MIDDLE EAST, ABUDHABI		DATE: 22-06-2020	
SITE: SERCO ACCOMONDATION, ABUDHABI		SAMPLED BY: CRYSTALLINE REP	
POTABLE WATER ANALYSIS			
PARAMETER	CONTROL LIMITS	RCC TANK BASEMENT	
pH at 25°C	7.0 – 9.2	8.73	
Conductivity at 25°C, µs/cm	--	235	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	152	
Total Hardness, ppm as CaCO ₃	300 Max.	67	
Calcium Hardness, ppm as CaCO ₃	200 Max.	54	
Chloride, ppm as Cl ⁻	250 Max.	51	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	<10	
Fluorides (F)	1.5 Max	<0.05	
Treatment Residuals			
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1.0	
*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).			
COMMENTS:		ACTION:	
The pH and Conductivity/TDS are found satisfactory. ⇨		No action recommended.	
Dissolved iron levels are within control limits ⇨		No action recommended.	
Service Engineer:	MURUGARAJ P	Client:	M/S: SERCO, MIDDLE EAST, ABUDHABI
Signature:		Signature:	






CONSULTING SERVICE REPORT

CUSTOMER: SERCO, MIDDLE EAST, ABUDHABI		DATE: 22-06-2020	
SITE: SERCO ACCOMONDATION, ABUDHABI		SAMPLED BY: CRYSTALLINE REP	
POTABLE WATER ANALYSIS			
PARAMETER	CONTROL LIMITS	POTABLE WATER APPARTMENT 102 (Cold Water Outlet)	
pH at 25°C	7.0 – 9.2	8.26	
Conductivity at 25°C, µs/cm	--	225	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	146	
Total Hardness, ppm as CaCO ₃	300 Max.	79	
Calcium Hardness, ppm as CaCO ₃	200 Max.	68	
Chloride, ppm as Cl ⁻	250 Max.	63	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	<10	
Fluorides (F)	1.5 Max	<0.05	
Treatment Residuals			
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1.0	
*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).			
COMMENTS:		ACTION:	
The pH and Conductivity/TDS are found satisfactory. ⇒		No action recommended.	
Dissolved iron levels are within control limits ⇒		No action recommended.	
Service Engineer:	MURUGARAJ P	Client:	M/S: SERCO, MIDDLE EAST, ABUDHABI
Signature:		Signature:	





CONSULTING SERVICE REPORT

CUSTOMER: SERCO, MIDDLE EAST, ABUDHABI		DATE: 22-06-2020	
SITE: SERCO ACCOMONDATION, ABUDHABI		SAMPLED BY: CRYSTALLINE REP	
POTABLE WATER ANALYSIS			
PARAMETER	CONTROL LIMITS	POTABLE WATER APPARTMENT 202 (Cold Water Outlet)	
pH at 25°C	7.0 – 9.2	8.56	
Conductivity at 25°C, µs/cm	--	220	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	143	
Total Hardness, ppm as CaCO ₃	300 Max.	80	
Calcium Hardness, ppm as CaCO ₃	200 Max.	71	
Chloride, ppm as Cl ⁻	250 Max.	65	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	<10	
Fluorides (F)	1.5 Max	<0.05	
Treatment Residuals			
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1.0	
*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).			
COMMENTS:		ACTION:	
The pH and Conductivity/TDS are found satisfactory. ⇨		No action recommended.	
Dissolved iron levels are within control limits ⇨		No action recommended.	
Service Engineer:	MURUGARAJ P	Client:	M/S: SERCO, MIDDLE EAST, ABUDHABI
Signature:		Signature:	





CONSULTING SERVICE REPORT

CUSTOMER: SERCO, MIDDLE EAST, ABUDHABI		DATE: 22-06-2020	
SITE: SERCO ACCOMONDATION, ABUDHABI		SAMPLED BY: CRYSTALLINE REP	
POTABLE WATER ANALYSIS			
PARAMETER	CONTROL LIMITS	HOT WATER APPARTMENT 202(Hot Water Outlet)	
pH at 25°C	7.0 – 9.2	8.24	
Conductivity at 25°C, µs/cm	--	210	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	136	
Total Hardness, ppm as CaCO ₃	300 Max.	78	
Calcium Hardness, ppm as CaCO ₃	200 Max.	64	
Chloride, ppm as Cl ⁻	250 Max.	59	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	<10	
Fluorides (F)	1.5 Max	<0.05	
Treatment Residuals			
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1.0	
*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).			
COMMENTS:		ACTION:	
The pH and Conductivity/TDS are found satisfactory. ⇨		No action recommended.	
Dissolved iron levels are within control limits ⇨		No action recommended.	
Zinc levels are satisfactory. ⇨		No action recommended.	
Service Engineer:	MURUGARAJ P	Client:	M/S: SERCO, MIDDLE EAST, ABUDHABI
Signature:		Signature:	





Legionella Test Report

Customer Details

Report No. WA-R-L-2006-12119

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2006-01863 Sample No. : WA-S-L-2006-11704

Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Apartment 202
Sampling Point	: Hot Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2006-12117

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11703
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Apartment 202
Sampling Point	: Cold Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2006-12115

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11702
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Apartment 102
Sampling Point	: Cold Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2006-12113

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11701
Sampling Date	: 22/06/2020	Report Date.	: 2/7/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 2/7/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Main Tank
Sampling Point	: Basement	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12120

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11704
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Apartment 202
Sampling Point	: Hot Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.



Microbiology Test Report

Report No. : WA-R-L-2006-12120

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12118

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11703
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Apartment 202
Sampling Point	: Cold Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.



Microbiology Test Report

Report No. : WA-R-L-2006-12118

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12116

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11702
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Apartment 102
Sampling Point	: Cold Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.



Microbiology Test Report

Report No. : WA-R-L-2006-12116

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2006-12114

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-L-2006-01863	Sample No.	: WA-S-L-2006-11701
Sampling Date	: 22/06/2020	Report Date.	: 27/6/2020
Analysis Start Date.	: 22/06/2020	Analysis End Date.	: 25/6/2020
Sample Location.	: Serco Accommodation	Sampled By	: Client Representative
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Main Tank
Sampling Point	: Basement	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.



Microbiology Test Report

Report No. : WA-R-L-2006-12114

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -