

TEST REPORT

Report No: QMTL/R-94323/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94323	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Shower P1, Male Physio - Wash Room		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/09:30 AM
Sample Container	1x500ml PB	Sampling Point	Shower Head
Sample Receipt Temp	5°C	Sample Onsite Temp	22.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction			
Test method deviation	None			
Test performed by Emp#	55 & 78 & 74			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94329/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94329	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Shower - Level 01, OT Male Change Room (Wash Room)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/10:02 AM
Sample Container	1x500ml PB	Sampling Point	Shower
Sample Receipt Temp	5°C	Sample Onsite Temp	20.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction			
Test method deviation	None			
Test performed by Emp#	55 & 78 & 74			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94332/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94332	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Shower - L2, Wooridul Wash Room (Male Changing Room)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/10:23 AM
Sample Container	1x500ml PB	Sampling Point	Shower
Sample Receipt Temp	5°C	Sample Onsite Temp	21.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94330/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94330
	Date Received	20 Feb 2020
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020
	Date Reported	29 Feb 2020
Sample Description	Shower - Level 3, Patient Ward, Room No: 326	
Sample Type	Water	Sampling Method QMTL-WI-15
Client Name/Project	NP	Sampled By QMTL Representative
Location	AUH	Sampling Date/Time 20.02.2020/10:08 AM
Sample Container	1x500ml PB	Sampling Point Shower
Sample Receipt Temp	5°C	Sample Onsite Temp 21.3°C
Sample Appearance	Clear	On-site Treatment NA
Reference	HEALTHPOINT HOSPITAL	

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT