

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: SERCO FACILITY MANAGEMENT, ABU DHABI			
Site Name:	Zayed University	Visit Date:	18-12-2019
Sampled By:	Crystalline Rep.	Sample Point	Main Swimming Pool
Source of Sample	Swimming Pool		

TEST RESULT			
No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.59
2	Conductivity at 25°C, µs/cm	---	437
3	TDS, ppm	Max 1500	284
4	Alkalinity	80 - 120	71
5	Calcium Hardness	200 - 500	138
6	Residual Chlorine	1.0 - 3.0	1.12
7	Cyanuric Acid	20 - 60	14
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS
<ul style="list-style-type: none"> pH level is satisfactory – No action recommended. Alkalinity & Cyanuric acid levels are low – Please maintain the desired limit.

Reported By,

P. Murugara
Murugara
Service Engineer

