



# CRYSTALLINE ENVIRONMENTAL SERVICES

## **CONSULTING TEST REPORT**

<b>Client Name: SERCO, MIDDLE EAST, ABUDHABI</b>			
<b>Site Name:</b>	<b>RIHAN HEIGHTS</b>	<b>Visit Date:</b>	<b>10-03-2021</b>
<b>Source of Sample</b>	<b>Swimming Pool</b>	<b>Sample Point</b>	<b>Main Swimming Pool</b>

### SWIMMING POOL ANALYSIS


No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.39
2	Conductivity at 25°C, µs/cm	---	962
3	TDS, ppm	Max 1500	625
4	Alkalinity	80 - 120	94
5	Calcium Hardness	200 - 500	242
6	Residual Chlorine	1.0 - 3.0	1.27
7	Cyanuric Acid	20 - 60	36
8	Dip slide	<10 <sup>3</sup>	ND

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### **COMMENTS AND RECOMMENDATIONS**

- All Parameters are within control limit – No action recommended

Reported By

  
Murugaraaj  
Service Engineer

