

CONSULTING SERVICE REPORT

Client: Serco Middle East

Project : Zayed University, Abu Dhabi

Sampling Location: Zayed University, Abu Dhabi

Date: 06-06- 2021

Sampling Point: Main Swimming Pool

Sampled By: Crystalline Representative

SWIMMING POOL WATER ANALYSIS

PARAMETER	CONTROL LIMITS	MAIN POOL	STATUS
pH	7.2 - 7.6	7.51	SATISFACTORY
TDS, ppm	Max 1000	826	SATISFACTORY
'P' Alkalinity, ppm as CaCO ₃	70 - 100	536	SATISFACTORY
Calcium Hardness, ppm as CaCO ₃	100 - 500	148	SATISFACTORY
Treatment Residuals			
Dipslide	<10 ³	ND	SATISFACTORY
Free Chlorine as Cl, mg/l	1.0 - 2.0	1.28	SATISFACTORY
Bromine, mg/l	2.0 - 4.0	--	N/A
Cyanuric Acid	20 - 60	38	SATISFACTORY

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

RECOMMENDATION:

1. All Parameters are within control limit.

SUMMARY:

The water analysis indicates a stable system.

"Certified that the Water Analysis Results has been tested * in accordance with the Standard Method, APHA-AWWA-WPCF,"

Reported By:


Murugaraaj
Service Engineer



END OF REPORT