

CONSULTING SERVICE REPORT

Client: Tafawuq Facility Management

Project : Sas Al Nakheel, Abu Dhabi

Sampling Location: Sas Al Nakheel, Abu Dhabi

Date: 03- 08- 2021

Sampling Point: Main Swimming Pool

Sampled By: Crystalline Representative

SWIMMING POOL WATER ANALYSIS

PARAMETER	CONTROL LIMITS	MAIN POOL	STATUS
pH	7.2 - 7.6	7.31	SATISFACTORY
TDS, ppm	Max 1000	159	SATISFACTORY
'P' Alkalinity, ppm as CaCO ₃	70 - 100	82	SATISFACTORY
Calcium Hardness, ppm as CaCO ₃	100 - 500	162	SATISFACTORY
Treatment Residuals			
Dipslide	<10 ³	ND	SATISFACTORY
Free Chlorine as Cl, mg/l	1.0 - 2.0	1.43	SATISFACTORY
Bromine, mg/l	2.0 - 4.0	--	N/A
Cyanuric Acid	20 - 60	32	SATISFACTORY

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

RECOMMENDATION:


- All Parameters are within control limit.

SUMMARY:

The water analysis indicates a stable system.

"Certified that the Water Analysis Results has been tested * in accordance with the Standard Method, APHA-AWWA-WPCF,"

Reported By:


Murugaraaj
Service Engineer



END OF REPORT

CONSULTING SERVICE REPORT

Client: Tafawuq Facility Management

Project : Sas Al Nakheel, Abu Dhabi

Sampling Location: Sas Al Nakheel, Abu Dhabi

Date: 03- 08- 2021

Sampling Point: Kids Swimming Pool

Sampled By: Crystalline Representative

SWIMMING POOL WATER ANALYSIS

PARAMETER	CONTROL LIMITS	MAIN POOL	STATUS
pH	7.2 - 7.6	7.38	SATISFACTORY
TDS, ppm	Max 1000	163	SATISFACTORY
'P' Alkalinity, ppm as CaCO ₃	70 - 100	84	SATISFACTORY
Calcium Hardness, ppm as CaCO ₃	100 - 500	161	SATISFACTORY
Treatment Residuals			
Dipslide	<10 ³	ND	SATISFACTORY
Free Chlorine as Cl, mg/l	1.0 - 2.0	1.39	SATISFACTORY
Bromine, mg/l	2.0 - 4.0	--	N/A
Cyanuric Acid	20 - 60	30	SATISFACTORY

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

RECOMMENDATION:


- All Parameters are within control limit.

SUMMARY:

The water analysis indicates a stable system.

"Certified that the Water Analysis Results has been tested * in accordance with the Standard Method, APHA-AWWA-WPCF,"

Reported By:


Murugaraaj
Service Engineer



END OF REPORT