

## CONSULTING SERVICE REPORT

Client: Serco Middle East

Project: Zayed University, Abu Dhabi

Sampling Location: FSP Building

Date: 10-08-2021

Sampling Point: Main Swimming Pool

Sampled By: Crystalline Representative

### SWIMMING POOL WATER ANALYSIS

PARAMETER	CONTROL LIMITS	MAIN POOL	STATUS
pH	7.2 - 7.6	7.53	SATISFACTORY
TDS, ppm	Max 1000	318	SATISFACTORY
'P' Alkalinity, ppm as CaCO <sub>3</sub>	70 - 100	84	SATISFACTORY
Calcium Hardness, ppm as CaCO <sub>3</sub>	100 - 500	172	SATISFACTORY
<b>Treatment Residuals</b>			
Dipslide	<10 <sup>3</sup>	ND	SATISFACTORY
Free Chlorine as Cl, mg/l	1.0 - 2.0	1.36	SATISFACTORY
Bromine, mg/l	2.0 - 4.0	--	N/A
Cyanuric Acid	20 - 60	30	SATISFACTORY

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (μmhos).

#### RECOMMENDATION:


- All Parameters are within control limit.

#### SUMMARY:

The water analysis indicates a stable system.

"Certified that the Water Analysis Results has been tested \* in accordance with the Standard Method, APHA-AWWA-WPCF,"

Reported By:

  
Murugaraaj  
Service Engineer



END OF REPORT