

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: SERCO MIDDLE EAST, ABU DHABI			
Site Name:	RIHAN HEIGHTS	Visit Date:	25-02-2020
Sampled By:	Crystalline Rep.	Sample Point	Main Swimming Pool
Source of Sample	Swimming Pool		

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.41
2	Conductivity at 25°C, µs/cm	---	836
3	TDS, ppm	Max 1500	543
4	Alkalinity	80 - 120	86
5	Calcium Hardness	200 - 500	209
6	Residual Chlorine	1.0 - 3.0	1.23
7	Cyanuric Acid	20 - 60	50
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.

Reported By,

Murugaraj
Service Engineer

