

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	RIHAN HEIGHTS	Visit Date:	04-05-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT			
No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.54
2	Conductivity at 25°C, µs/cm	---	853
3	TDS, ppm	Max 1500	554
4	Alkalinity	80 - 120	83
5	Calcium Hardness	200 - 500	234
6	Residual Chlorine	1.0 - 3.0	1.04
7	Cyanuric Acid	20 - 60	24
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS
<ul style="list-style-type: none"> Parameters are within control limit – No action Recommended.

Reported By,
Murugaraj
Murugaraj
Service Engineer

