

## SWIMMING POOL - WATER ANALYSIS REPORT

<b>Client Name:</b> SERCO MIDDLE EAST, ABU DHABI			
<b>Site Name:</b>	RIHAN HEIGHTS	<b>Visit Date:</b>	04-03-2020
<b>Sampled By:</b>	Crystalline Rep.	<b>Sample Point</b>	Main Swimming Pool
<b>Source of Sample</b>	Swimming Pool		


### TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.56
2	Conductivity at 25°C, µs/cm	---	815
3	TDS, ppm	Max 1500	529
4	Alkalinity	80 - 120	92
5	Calcium Hardness	200 - 500	204
6	Residual Chlorine	1.0 - 3.0	1.16
7	Cyanuric Acid	20 - 60	42
8	Dip slide	<10 <sup>3</sup>	ND

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.

Reported By,  
  
 Murugaraj  
 Service Engineer

