



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO MIDDLE EAST

Site Name:	ZAYED UNIVERSITY	Visit Date:	08-11-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT


No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.43
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	---	553
3	TDS, ppm	Max 1500	359
4	Alkalinity	80 - 120	87
5	Calcium Hardness	200 - 500	224
6	Residual Chlorine	1.0 - 3.0	1.36
7	Cyanuric Acid	20 - 60	34
8	Dip slide	$<10^3$	ND

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- Parameters are within control limit – No action Recommended.

Reported By,


Murugaraj
Service Engineer



CLEANER WATER GREENER TOMORROW