

Swimming Pool Analysis Report


CUSTOMER: SERCO MIDDLE EAST			
Site Name:	ZAYED UNIVERSITY	Visit Date:	10-03-2021
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

Test Result			
No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.53
2	Conductivity at 25°C, µs/cm	---	514
3	TDS, ppm	Max 1500	334
4	Alkalinity	80 - 120	86
5	Calcium Hardness	200 - 500	228
6	Residual Chlorine	1.0 - 3.0	1.16
7	Cyanuric Acid	20 - 60	21
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.

Reported By,


Murugaraj
Service Engineer

