

TEST REPORT

Report No: QMTL/R-94514/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-94514	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 24 Feb 2020	
	Date Reported	27 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	Tower 1, Potable Water - Roof Top, Tank -1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	5°C	Sample Onsite Temp	25.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM-ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable; NP: Not Provided, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 78
------------------------	---------

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94515/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-94515	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 24 Feb 2020	
	Date Reported	27 Feb 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	Tower 1, Potable Water - Roof Top, Tank -2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/10:50 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	5°C	Sample Onsite Temp	26°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM-ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable; NP: Not Provided, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94516/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94516		
	Date Received	22 Feb 2020		
	Date(s) Tested	22 Feb 2020 - 24 Feb 2020		
	Date Reported	27 Feb 2020		
Sample Description	Tower - 1 R1, Transfer Pump Room Tank - 1			
Sample Type	Water	Sampling Method	QMTL-WI-15	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	AUH	Sampling Date/Time	22.02.2020/11:05 AM	
Sample Container	1x500ml PB	Sampling Point	Tank	
Sample Receipt Temp	5°C	Sample Onsite Temp	28°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	ADGM-ABU DHABI			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable; NP: Not Provided, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94517/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94517	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 24 Feb 2020	
	Date Reported	27 Feb 2020	
Sample Description	Tower - 1 R1, Transfer Pump Room Tank - 2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/11:20 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	5°C	Sample Onsite Temp	27.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM-ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable; NP: Not Provided, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94518/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94518	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 24 Feb 2020	
	Date Reported	27 Feb 2020	
Sample Description	Tower 1 R1, Plumbing Room Tank - 4		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/11:45 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	5°C	Sample Onsite Temp	29.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM-ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable; NP: Not Provided, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94536/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-94536
		Date Received	22 Feb 2020
		Date(s) Tested	22 Feb 2020 - 03 Mar 2020
ATTN : MR. JASMAN PINTO		Date Reported	04 Mar 2020
Sample Description	Tower - 1, R1, Transfer Pump Room Tank - 1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/11:05 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM- ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94537/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94537	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 03 Mar 2020	
	Date Reported	04 Mar 2020	
Sample Description	Tower - 1, R1, Transfer Pump Room Tank - 2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/11:20 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	27.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM- ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94538/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94538	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 03 Mar 2020	
	Date Reported	04 Mar 2020	
Sample Description	Tower 1, R1, Pumping Room Tank - 4		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/11:45 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	29.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM- ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94534/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94534	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 03 Mar 2020	
	Date Reported	04 Mar 2020	
Sample Description	Tower 1, Potable Water - Roof Top, Tank -1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/10:30 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	25.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM- ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94535/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94535	
	Date Received	22 Feb 2020	
	Date(s) Tested	22 Feb 2020 - 03 Mar 2020	
	Date Reported	04 Mar 2020	
Sample Description	Tower 1, Potable Water - Roof Top, Tank -2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	22.02.2020/10:50 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	26°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	ADGM- ABU DHABI		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

INDOOR AIR QUALITY MONITORING REPORT

REPORT NO: - QMTL/R-95571

CLIENT: M/S. CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi, U.A.E	
ATTN: MR.JASMAN PINTO	
PROJECT: INDOOR AIR QUALITY MONITORING AT ADGM BUILDING	
Sampling location: Near ESD, 7th floor, Tower-1,	Sample ID : QMTL/S-95571
Sampling Method: BSEN 481:1993,60079-29-2-2015	Date(s) Tested:27.02.2020
Date/Time of Sampling:27.02.2020	Sampling Duration: STEL Date Of Reporting:29.02.2020

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
PARTICULATE MATTER				
PM 1.0	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	0.4
PM 2.5	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 15	1.2
PM 10	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 50	30.4
TSPM	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	61.3
GASEOUS				
TVOC	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	-	0.09
Carbon Dioxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 700	642
Carbon Monoxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 9	1.3



Report No: QMTL/R-95571
Sample No: QMTL/S-95571

Date Reported: 29.02.2020
Date Received: 27.02.2020

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
Temperature	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	°C	-	24.0
Humidity	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	%	Max 65	49.2

Remarks: The indoor quality performed meets with ANSI/ASHRAE standard 62.1-2016 for Ventilation for Acceptable Indoor Air Quality guideline with respect to the above tested parameters

Analysis performed by : 65
Report prepared by : 39
Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

INDOOR AIR QUALITY MONITORING REPORT

REPORT NO: - QMTL/R-95572

CLIENT: M/S. CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi, U.A.E		
ATTN: MR.JASMAN PINTO		
PROJECT: INDOOR AIR QUALITY MONITORING AT ADGM BUILDING		
Sampling location: Near Clifford Chance, 9th floor, Tower-1	Sample ID : QMTL/S-95572	
Sampling Method: BSEN 481:1993,60079-29-2-2015	Date(s) Tested:27.02.2020	
Date/Time of Sampling:27.02.2020	Sampling Duration: STEL	Date Of Reporting:29.02.2020

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
PARTICULATE MATTER				
PM 1.0	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	0.2
PM 2.5	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 15	1.7
PM 10	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 50	15.9
TSPM	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	34.3
GASEOUS				
TVOC	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	-	0.09
Carbon Dioxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 700	672
Carbon Monoxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 9	1.3



Report No: QMTL/R-95572
Sample No: QMTL/S-95572

Date Reported: 29.02.2020
Date Received: 27.02.2020

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
Temperature	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	°C	-	23.4
Humidity	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	%	Max 65	48.6

Remarks: The indoor quality performed meets with ANSI/ASHRAE standard 62.1-2016 for Ventilation for Acceptable Indoor Air Quality guideline with respect to the above tested parameters

Analysis performed by : 65
Report prepared by : 39
Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

INDOOR AIR QUALITY MONITORING REPORT

REPORT NO: - QMTL/R-95573

CLIENT: M/S. CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi, U.A.E		
ATTN: MR.JASMAN PINTO		
PROJECT: INDOOR AIR QUALITY MONITORING AT ADGM BUILDING		
Sampling location: Near Citi Bank, 15th floor, Tower-1	Sample ID : QMTL/S-95573	
Sampling Method: BSEN 481:1993,60079-29-2-2015	Date(s) Tested:27.02.2020	
Date/Time of Sampling:27.02.2020	Sampling Duration: STEL	Date Of Reporting:29.02.2020

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
PARTICULATE MATTER				
PM 1.0	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	0.6
PM 2.5	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 15	1.7
PM 10	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 50	9.4
TSPM	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	15.5
GASEOUS				
TVOC	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	-	0.05
Carbon Dioxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 700	572
Carbon Monoxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 9	1.0



Report No: QMTL/R-95573
 Sample No: QMTL/S-95573

Date Reported: 29.02.2020
 Date Received: 27.02.2020

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
Temperature	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	°C	-	23.1
Humidity	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	%	Max 65	50.3

Remarks: The indoor quality performed meets with ANSI/ASHRAE standard 62.1-2016 for Ventilation for Acceptable Indoor Air Quality guideline with respect to the above tested parameters

Analysis performed by : 65
 Report prepared by : 39
 Test Method deviation : None
 The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

INDOOR AIR QUALITY MONITORING REPORT

REPORT NO: - QMTL/R-95574

CLIENT: M/S. CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi, U.A.E	
ATTN: MR.JASMAN PINTO	
PROJECT: INDOOR AIR QUALITY MONITORING AT ADGM BUILDING	
Sampling location: Regus Reception, 24th floor, Tower-1	Sample ID : QMTL/S-95574
Sampling Method: BSEN 481:1993,60079-29-2-2015	Date(s) Tested:27.02.2020
Date/Time of Sampling:27.02.2020	Sampling Duration: STEL
	Date Of Reporting:29.02.2020

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
PARTICULATE MATTER				
PM 1.0	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	0.3
PM 2.5	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 15	0.9
PM 10	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 50	4.9
TSPM	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	10.3
GASEOUS				
TVOC	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	-	0.03
Carbon Dioxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 700	593
Carbon Monoxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 9	0.8



Report No: QMTL/R-95574
Sample No: QMTL/S-95574

Date Reported: 29.02.2020
Date Received: 27.02.2020

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
Temperature	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	°C	-	22.9
Humidity	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	%	Max 65	50.3

Remarks: The indoor quality performed meets with ANSI/ASHRAE standard 62.1-2016 for Ventilation for Acceptable Indoor Air Quality guideline with respect to the above tested parameters

Analysis performed by : 65
Report prepared by : 39
Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

INDOOR AIR QUALITY MONITORING REPORT

REPORT NO: - QMTL/R-95575

CLIENT: M/S. CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi, U.A.E		
ATTN: MR.JASMAN PINTO		
PROJECT: INDOOR AIR QUALITY MONITORING AT ADGM BUILDING		
Sampling location: Unicredit Reception, 27th floor, Tower-1	Sample ID : QMTL/S-95575	
Sampling Method: BSEN 481:1993,60079-29-2-2015	Date(s) Tested:27.02.2020	
Date/Time of Sampling:27.02.2020	Sampling Duration: STEL	Date Of Reporting:29.02.2020

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
PARTICULATE MATTER				
PM 1.0	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	0.3
PM 2.5	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 15	0.6
PM 10	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	Max 50	27.8
TSPM	BSEN 481:1993, QMTL-SOP-147 Rev 01 Dated 20.08.2019	µg/m ³	-	40.9
GASEOUS				
TVOC	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	-	0.04
Carbon Dioxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 700	599
Carbon Monoxide	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	ppm	Max 9	1.1



Report No: QMTL/R-95575
 Sample No: QMTL/S-95575

Date Reported: 29.02.2020
 Date Received: 27.02.2020

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
Temperature	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	°C	-	23.1
Humidity	BSEN 60079-29-2-2015, QMT- SOP-146 Rev 01 Dated 20.08.2019	%	Max 65	50.6

Remarks: The indoor quality performed meets with ANSI/ASHRAE standard 62.1-2016 for Ventilation for Acceptable Indoor Air Quality guideline with respect to the above tested parameters

Analysis performed by : 65
 Report prepared by : 39
 Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT