

TEST REPORT

Report No: QMTL/R-148321/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148321
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:20 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	38°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	2
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148320/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148320
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:10 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	39°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	3
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148319/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148319
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -3		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	37°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148318/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148318
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -4		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:55 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	38°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148313/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148313
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -5		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	30°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148314/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148314
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -6		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:05 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148315/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148315
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -7		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 11:00 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	3
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148316/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148316
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -8		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:40 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	16°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	4
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148317/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148317
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Potable Water, Tank -9		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:50 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	31°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	5
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers (HAAD/HSED/ST/0012/HS_EHSMS) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148372/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148372	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Potable Water, Tank -1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:20 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	38°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148371/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-148371	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
Sample Description	Potable Water, Tank -2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:10 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	39°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148370/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148370	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Potable Water, Tank -3		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:00 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	37°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148369/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148369	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Potable Water, Tank -4		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:55 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	38°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pnueumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnueumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148364/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148364
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Potable Water, Tank -5		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:00 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	30°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148365/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148365	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Potable Water, Tank -6		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:05 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148366/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148366	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Potable Water, Tank -7		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:30 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	29°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148367/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-148367	
	Date Received	14 Feb 2021	
	Date(s) Tested	14 Feb 2021 - 24 Feb 2021	
	Date Reported	03 Mar 2021	
Sample Description	Potable Water, Tank -8		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:40 M
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	16°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-148368/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148368
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Potable Water, Tank -9		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:50 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	31°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT