



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33320



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32856

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 27	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Podium Level 3 Pump Room Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 19

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33313



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32849

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3656	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 12

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33314



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32850

Sampling Date	: 23/01/2021	Report Date.	: 26/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 25/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3656	Sampling Method	: APHA 9060 A&B
Temperature °C	: 25	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Water Tank 2
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 13

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS/software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33315



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32851

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3656	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Water Tank 3
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 14

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33316



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32852

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Wash Room
Sampling Point	: Tap Water	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 15

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33358



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32894

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 27	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Podium Level 3 Pump Room Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 19

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33351



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32887

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3656	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 12

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33352



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32888

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3656	Sampling Method	: APHA 9060 A&B
Temperature °C	: 25	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Water Tank 2
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 13

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33353



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32889

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3656	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Water Tank 3
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 14

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33354



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32890

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower C Level 17 Wash Room
Sampling Point	: Tap Water	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 15

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower C, Level-P3 Pump Room	Visit Date:	23-01-2021
Sample Point	Water Tank	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.14
2	Conductivity at 25°C, µs/cm	----	232
3	Total Dissolved Solids (TDS)	Max 1000	150
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	51
7	Total Hardness at 25°C	300	63
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	41
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By


Murugaraa
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower C, Level- 17	Visit Date:	23-01-2021
Sample Point	Water Tank # 01	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.09
2	Conductivity at 25°C, μ s/cm	----	224
3	Total Dissolved Solids (TDS)	Max 1000	145
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	63
7	Total Hardness at 25°C	300	65
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	39
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By


Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower C, Level- 17	Visit Date:	23-01-2021
Sample Point	Water Tank # 02	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.13
2	Conductivity at 25°C, μ S/cm	----	229
3	Total Dissolved Solids (TDS)	Max 1000	148
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	57
7	Total Hardness at 25°C	300	66
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	41
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By


Murugaraaj
Service Engineer





CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower C, Level- 17	Visit Date:	23-01-2021
Sample Point	Water Tank # 03	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.16
2	Conductivity at 25°C, μ s/cm	----	235
3	Total Dissolved Solids (TDS)	Max 1000	152
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	54
7	Total Hardness at 25°C	300	58
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	32
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By

Murugaraa
Service Engineer





CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower C, Level- 17	Visit Date:	23-01-2021
Sample Point	Wash Room - Tap Water	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.31
2	Conductivity at 25°C, µs/cm	----	219
3	Total Dissolved Solids (TDS)	Max 1000	142
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	53
7	Total Hardness at 25°C	300	61
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	38
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By

Murugaraa

Murugaraa
Service Engineer

