



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33322



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32858

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Podium Level 3 Pump Room Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 21

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33326



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32862

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 25

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33327



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32863

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Water Tank 2
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 26

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33328



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32864

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 24	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Water Tank 3
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 27

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSE Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33329



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32865

Sampling Date	: 23/01/2021	Report Date.	: 27/01/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 26/01/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Waste Room
Sampling Point	: Tap Water	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 28

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33360



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32896

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Podium Level 3 Pump Room Water Tank 1
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 21

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33364



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32900

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Water Tank i
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 25

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Musaffah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33365



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32901

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Water Tank 2
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 26

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33366



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32902

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 24	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Water Tank 3
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 27

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-33367



Request No. : WA-Q-L-2101-04693

Sample No. : WA-S-L-2101-32903

Sampling Date	: 23/01/2021	Report Date.	: 02/02/2021
Analysis Start Date.	: 23/01/2021	Analysis End Date.	: 02/02/2021
Sample Location.	: Rihan Heights	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: water
Sample Certificate No	: 3657	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Tower E Level 21 Waste Room
Sampling Point	: Tap Water	Preservation	: 4-8°C
Sample Description	: Water	sampler ref. no.	: 28

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower E, Level-P3 Pump Room	Visit Date:	23-01-2021
Sample Point	Water Tank	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.63
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	272
3	Total Dissolved Solids (TDS)	Max 1000	176
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	56
7	Total Hardness at 25°C	300	64
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	47
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By

Murugaraa
Service Engineer



CLEANER WATER GREENER TOMORROW



CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower E, Level - 21	Visit Date:	23-01-2021
Sample Point	Water Tank # 01	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.19
2	Conductivity at 25°C, μ s/cm	----	243
3	Total Dissolved Solids (TDS)	Max 1000	157
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	61
7	Total Hardness at 25°C	300	67
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	44
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By


Murugaraaj
Service Engineer





CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower E, Level - 21	Visit Date:	23-01-2021
Sample Point	Water Tank # 02	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.41
2	Conductivity at 25°C, μ s/cm	----	267
3	Total Dissolved Solids (TDS)	Max 1000	173
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	61
7	Total Hardness at 25°C	300	66
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	43
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By

Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower E, Level - 21	Visit Date:	23-01-2021
Sample Point	Water Tank # 03	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.26
2	Conductivity at 25°C, µs/cm	----	241
3	Total Dissolved Solids (TDS)	Max 1000	156
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	56
7	Total Hardness at 25°C	300	62
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	47
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By


Murugaraaj
Service Engineer





CONSULTING TEST REPORT

Client Name: SERCO, MIDDLE EAST, ABUDHABI			
Site Name:	Rihan Heights		
Sample Location	Tower E, Level - 21	Visit Date:	23-01-2021
Sample Point	Waste Room - Tap Water	Sampled By	Crystalline Rep

PORTABLE WATER ANALYSIS

	Parameter	Control Limits	Results
1	pH at 25°C	7.0 - 9.2	8.52
2	Conductivity at 25°C, μ s/cm	----	243
3	Total Dissolved Solids (TDS)	Max 1000	157
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	64
7	Total Hardness at 25°C	300	69
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	47
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By


Murugaraa
Service Engineer

