



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28886



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28273

Sampling Date	: 10/12/2020	Report Date.	: 13/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 13/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Bay 05
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28885



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28272

Sampling Date	: 10/12/2020	Report Date.	: 13/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 13/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Hanger 05
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28884



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28271

Sampling Date	: 10/12/2020	Report Date.	: 13/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 13/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Hanger 04
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28883



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28270

Sampling Date	: 10/12/2020	Report Date.	: 13/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 12/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Utility
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28882



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28269

Sampling Date	: 10/12/2020	Report Date.	: 13/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 12/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Aviation
Sampling Point	: Valve	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -