



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28891



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28278

Sampling Date	: 10/12/2020	Report Date.	: 20/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 20/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Bay 05
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28890



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28277

Sampling Date	: 10/12/2020	Report Date.	: 20/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 20/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Hanger 05
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28889



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28276

Sampling Date	: 10/12/2020	Report Date.	: 20/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 20/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Hanger 04
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28888



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28275

Sampling Date	: 10/12/2020	Report Date.	: 20/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 20/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Utility
Sampling Point	: Tap	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28887



Request No. : WA-Q-L-2012-04110

Sample No. : WA-S-L-2012-28274

Sampling Date	: 10/12/2020	Report Date.	: 20/12/2020
Analysis Start Date.	: 10/12/2020	Analysis End Date.	: 20/12/2020
Sample Location.	: Etihad Airways Engineering	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2981	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Plastic Bottle	Source of Sample	: Aviation
Sampling Point	: Valve	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -