



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31421



Request No. : WA-Q-L-2101-04442

Sample No. : WA-S-L-2101-30772

Sampling Date	: 04/01/2021	Report Date.	: 14/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 14/01/2021
Sample Location.	: Etihad Airways, Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3358	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Bay - 06
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31420



Request No. : WA-Q-L-2101-04442

Sample No. : WA-S-L-2101-30771

Sampling Date	: 04/01/2021	Report Date.	: 14/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 14/01/2021
Sample Location.	: Etihad Airways, Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3358	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Hanger -06
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31419



Request No. : WA-Q-L-2101-04442

Sample No. : WA-S-L-2101-30770

Sampling Date	: 04/01/2021	Report Date.	: 14/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 14/01/2021
Sample Location.	: Etihad Airways, Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3358	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Hanger -04
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31418



Request No. : WA-Q-L-2101-04442

Sample No. : WA-S-L-2101-30769

Sampling Date	: 04/01/2021	Report Date.	: 14/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 14/01/2021
Sample Location.	: Etihad Airways, Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3358	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Utility
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31417



Request No. : WA-Q-L-2101-04442

Sample No. : WA-S-L-2101-30768

Sampling Date	: 04/01/2021	Report Date.	: 14/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 14/01/2021
Sample Location.	: Etihad Airways, Abu Dhabi	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3358	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Aviation
Sampling Point	: Not Given	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -