



**Microbiology Test Report**

**Customer Details**

**Crystalline Environmental Services**

Report No. WA-R-L-2005-8935



Request No.	: WA-Q-L-2005-1420	Sample No.	: WA-S-L-2005-8730
Sampling Date/time	: 12/5/2020 , 14:19	Report Date.	: 14/5/2020
Analysis Start Date.	: 12/5/2020	Analysis End Date.	: 14/5/2020
Sample Location.	: Al Maryah Tower, Abu Dhabi	Sampled By	: Client Representative
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Basement (P3)
Sampling Point	: Pantry Tap Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= $\leq$ 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

Report No. WA-R-L-2005-8934

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1420	Sample No.	: WA-S-L-2005-8730
Sampling Date/time	: 12/5/2020 , 14:19	Report Date.	: 26/5/2020
Analysis Start Date.	: 12/5/2020	Analysis End Date.	: 22/5/2020
Sample Location.	: Al Maryah Tower, Abu Dhabi	Sampled By	: Client Representative
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: Basement (P3)
Sampling Point	: Pantry Tap Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Microbiology Test Report**

**Customer Details**

Report No. WA-R-L-2005-8933

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1420	Sample No.	: WA-S-L-2005-8729
Sampling Date/time	: 12/5/2020 , 14:19	Report Date.	: 14/5/2020
Analysis Start Date.	: 12/5/2020	Analysis End Date.	: 14/5/2020
Sample Location.	: Al Maryah Tower, Abu Dhabi	Sampled By	: Client Representative
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: 24th Floor
Sampling Point	: Tap Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

Report No. WA-R-L-2005-8932

**Crystalline Environmental Services**



Request No.	: WA-Q-L-2005-1420	Sample No.	: WA-S-L-2005-8729
Sampling Date/time	: 12/5/2020 , 14:19	Report Date.	: 26/5/2020
Analysis Start Date.	: 12/5/2020	Analysis End Date.	: 22/5/2020
Sample Location.	: Al Maryah Tower, Abu Dhabi	Sampled By	: Client Representative
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: Not Applicable	Sampling Method	: Not Applicable
Temperature °C	: Not Applicable	Site Observation	: Not Applicable
Sampling Container	: Plastic Bottle	Source of Sample	: 24th Floor
Sampling Point	: Tap Water	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
JY	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -