

TEST REPORT

Report No: QMTL/R-150338/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-150338
		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 26 Feb 2021
		Date Reported	06 Mar 2021
Sample Description	Main Utility Tank		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Ethihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	-	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150339/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150339
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 26 Feb 2021
		Date Reported	06 Mar 2021
Sample Description	Aviation Water		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Ethihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	-	5
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150340/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150340
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 26 Feb 2021
		Date Reported	06 Mar 2021
Sample Description	Hanger #5		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Ethihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	-	1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150347/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150347
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 26 Feb 2021
		Date Reported	06 Mar 2021
Sample Description	Hanger #6		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	-	15
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150348/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150348
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021
		Date Reported	06 Mar 2021
Sample Description	Bay #06		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	-	2
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150128/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150128
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 06 Mar 2021
		Date Reported	08 Mar 2021
Sample Description	Main Utility Tank		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pnueomophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnueomophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150130/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150130
		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 06 Mar 2021
ATTN : MR. JASMAN PINTO		Date Reported	08 Mar 2021
Sample Description	Aviation Water		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150131/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150131
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 06 Mar 2021
		Date Reported	08 Mar 2021
Sample Description	Hanger #5		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Ethihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pnueomophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnueomophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150200/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150200
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 06 Mar 2021
		Date Reported	08 Mar 2021
Sample Description	Hanger #6		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Ethihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pnueomophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pnueomophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-150351/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-150351
ATTN : MR. JASMAN PINTO		Date Received	24 Feb 2021
		Date(s) Tested	24 Feb 2021 - 06 Mar 2021
		Date Reported	08 Mar 2021
Sample Description	Bay #06		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	Etihad Airways Engineering	Sampling Date/Time	24.02.2021 / 10:30 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan-2021 requirements for potable water with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT