

## TEST REPORT

REPORT NO:-QMTL/R-89774

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89774
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Gate No. 1, Water Fountain Sample Onsite Temp: 28°C Sample Receipt Temp: 25°C	Source: Fountain	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
On-Site Treatment: NA	Sample Appearance: Clear	Date of Sampling/Time: NA
	Tested by Emp#: 55 & 78	Location: AUH

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Fountain Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

**TEST REPORT**

REPORT NO:-QMTL/R-89775

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89775
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Gate No. 2, Water Fountain Sample Onsite Temp: 28°C Sample Receipt Temp: 25°C	Source: Fountain	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: NA
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<1
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Fountain Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test-Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

## TEST REPORT

REPORT NO:-QMTL/R-89776

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89776
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Gate No. 3, Water Fountain Sample Onsite Temp: 28°C Sample Receipt Temp: 25°C	Source: Fountain	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: NA
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	<b>126</b>
Total Coliforms	APHA 9222 B	CFU/100ml	-	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	-	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	<b>Zero</b>

REMARKS: The sample meets DM Water Systems quality (2010) specifications for Fountain Water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

## TEST REPORT

REPORT NO:-QMTL/R-89777

**CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES**

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

**ATTN: Mr. JASMAN PINTO**

Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89777
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Cooler Maintenance Office Sample Onsite Temp: 22°C Sample Receipt Temp: 25°C	Source: Cooler	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
On-Site Treatment: NA	Sample Appearance: Clear	Date of Sampling/Time: NA
	Tested by Emp#: 55 & 78	Location: AUH

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>9</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**

**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-89778

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89778
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Cooler Male Changing Room Sample Onsite Temp: 22.1°C Sample Receipt Temp: 25°C	Source: Cooler	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: NA
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

## TEST REPORT

REPORT NO:-QMTL/R-89779

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89779
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Foot Ball Court Sample Onsite Temp: 22.2°C Sample Receipt Temp: 25°C	Source: Cooler	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
On-Site Treatment: NA	Sample Appearance: Clear	Date of Sampling/Time: NA
	Tested by Emp#: 55 & 78	Location: AUH

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<b>9</b>
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

**TEST REPORT**

REPORT NO:-QMTL/R-89780

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
<b>ATTN: Mr. JASMAN PINTO</b>		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89780
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Reception Club House Sample Onsite Temp: 22.8°C Sample Receipt Temp: 25°C	Source: Cooler	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: NA
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

**TEST RESULTS**

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**

## TEST REPORT

REPORT NO:-QMTL/R-89781

**CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES**

P.O.Box.131463, Abu Dhabi, U.A.E

Ph:02-6508930/0557167017

**ATTN: Mr. JASMAN PINTO**

Product: Water	Sampling Method: NA	Sample ID: QMTL/S-89781
Reference: SAS AL NAKHL	Sampled By: Client Representative	Date Received: 20.01.2020
<b>Sample Description:</b> Gym Area Water Sample Onsite Temp: 22.1°C Sample Receipt Temp: 25°C	Source: Cooler	Date(s) Tested: 20.01.2020-22.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 26.01.2020
On-Site Treatment: NA	Sample Appearance: Clear	Date of Sampling/Time: NA
	Tested by Emp#: 55 & 78	Location: AUH

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	SPECIFICATIONS	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	<b>Zero</b>
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	<b>Zero</b>
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	<b>Zero</b>

REMARKS: The sample meets RSB Water Quality Regulations (4<sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by subcontract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**