



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31422



Request No. : WA-Q-L-2101-04443

Sample No. : WA-S-L-2101-30773

Sampling Date	: 04/01/2021	Report Date.	: 07/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 06/01/2021
Sample Location.	: Al Bandar Village	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3359	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Main Fountain
Sampling Point	: Near Security Room	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	500CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31428



Request No. : WA-Q-L-2101-04443

Sample No. : WA-S-L-2101-30779

Sampling Date	: 04/01/2021	Report Date.	: 14/01/2021
Analysis Start Date.	: 04/01/2021	Analysis End Date.	: 14/01/2021
Sample Location.	: Al Bandar Village	Sampled By	: Client
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3359	Sampling Method	: Not Applicable
Temperature °C	: Not Given	Site Observation	: Not Given
Sampling Container	: Plastic Bottle	Source of Sample	: Main Fountain
Sampling Point	: Near Security Room	Preservation	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1CFU/L

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -