

TEST REPORT

Report No: QMTL/R-94115/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94115	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020	
	Date Reported	02 Mar 2020	
Sample Description	Potable Water - Tank -1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/01:21 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	26°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94116/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-94116
		Date Received	19 Feb 2020
		Date(s) Tested	19 Feb 2020 - 29 Feb 2020
ATTN : MR. JASMAN PINTO		Date Reported	02 Mar 2020
Sample Description	Potable Water - Tank -2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/01:30 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	25.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94117/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94117		
	Date Received	19 Feb 2020		
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020		
	Date Reported	02 Mar 2020		
Sample Description	Potable Water - Tank -3			
Sample Type	Water	Sampling Method	QMTL-WI-16	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	AUH	Sampling Date/Time	19.02.2020/01:45 PM	
Sample Container	1x1L PB	Sampling Point	Tank	
Sample Receipt Temp	16°C	Sample Onsite Temp	30.2°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	HEALTHPOINT HOSPITAL			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94118/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94118	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020	
	Date Reported	02 Mar 2020	
Sample Description	Potable Water - Tank -4		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/01:52 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	29.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94119/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94119	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020	
	Date Reported	02 Mar 2020	
Sample Description	Potable Water - Tank -5		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/02:30 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	29.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94120/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94120	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020	
	Date Reported	02 Mar 2020	
Sample Description	Potable Water - Tank -6		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/02:36 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	18.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94121/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94121		
	Date Received	19 Feb 2020		
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020		
	Date Reported	02 Mar 2020		
Sample Description	Potable Water - Tank -7			
Sample Type	Water	Sampling Method	QMTL-WI-16	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	AUH	Sampling Date/Time	19.02.2020/02:42 PM	
Sample Container	1x1L PB	Sampling Point	Tank	
Sample Receipt Temp	16°C	Sample Onsite Temp	29.2°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	HEALTHPOINT HOSPITAL			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94122/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94122		
	Date Received	19 Feb 2020		
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020		
	Date Reported	02 Mar 2020		
Sample Description	Potable Water - Tank -8			
Sample Type	Water	Sampling Method	QMTL-WI-16	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	AUH	Sampling Date/Time	19.02.2020/02:50 PM	
Sample Container	1x1L PB	Sampling Point	Tank	
Sample Receipt Temp	16°C	Sample Onsite Temp	16.1°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	HEALTHPOINT HOSPITAL			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, WI: Work Instruction, NP : Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-94123/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-94123	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 29 Feb 2020	
	Date Reported	02 Mar 2020	
Sample Description	Irrigation Tank No: 09		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/03:00 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	16°C	Sample Onsite Temp	31°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	100 (cfu/ml) (Circulating Water)	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets RSB Recycled Water and Biosolids Regulations 2018 requirements for irrigation water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT