

## SWIMMING POOL - WATER ANALYSIS REPORT

<b>Client Name: SERCO MIDDLE EAST</b>			
<b>Site Name:</b>	ZAYED UNIVERSITY	<b>Visit Date:</b>	25-06-2020
<b>Source of Sample</b>	Swimming Pool	<b>Sample Point</b>	Main Swimming Pool

### TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.36
2	Conductivity at 25°C, µs/cm	---	641
3	TDS, ppm	Max 1500	416
4	Alkalinity	80 - 120	89
5	Calcium Hardness	200 - 500	236
6	Residual Chlorine	1.0 - 3.0	1.42
7	Cyanuric Acid	20 - 60	37
8	Dip slide	<10 <sup>3</sup>	ND

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.

Reported By,

Murugan  
Service Engineer

